



ADDENDUM # 1

RFP # 112015

Bay County Court Facility
Roof Project

THOMAS HICKNER
BAY COUNTY EXECUTIVE

DATE OF ADDENDUM

JUNE 26, 2015

REFERENCE PROPOSAL NUMBER

RFP 112015

PROPOSAL DATE/TIME OPENING

JULY 7, 2015
1:00 P.M.

SUBMIT PROPOSAL TO

BAY COUNTY FINANCE DEPARTMENT
PURCHASING DIVISION
ATTN: FRANCES MOORE
BAY COUNTY BUILDING
515 CENTER AVENUE
BAY CITY, MI 48708-5128

MARK PROPOSAL

"BAY COUNTY COURT FACILITY ROOF
PROJECT" DELIVER TO THE PURCHASING
OFFICE IMMEDIATELY

ADDENDUM REGARDING: CLARIFICATION QUESTIONS & BID OPENING DATE CHANGE

ADDENDUM ISSUED BY:

Frances Moore
Purchasing Agent

1. Roof edge termination. Spec. only lists metal coping termination. The roofs do have a metal drip edge details. What is desired at these locations? Also, some parapet walls have both drip edge and coping cap. Should we match what is there or all parapet walls to have metal coping cap.

Existing coping/caps are to be replaced with new caps per specifications.

2. Walkway pads. Please verify locations desired and amount of feet of walk ways pads are wanted.

175 feet and to be placed as directed by Bay County Buildings & Grounds.

3. Please verify locations desired or amount of feet of safety perimeter if desired. Safety perimeter would be temporary.

The safety perimeter is temporary and is up to the contractor to provide as required by MIOSHA.

4. Existing insulation was stated to be 3" but bid summary attachment A states 2" .. should that be 3".

Insulation should be 3".

5. Per requirements of bidders #1. Is the County prevailing wage requirement Bacon Davis or State prevailing rates.

The project is based on the State of Michigan prevailing wage rates.

BID DATE CHANGE: THE DATE FOR THE BID OPENING HAS BEEN CHANGED TO JULY 7, 2015 AT 1:00 PM. THE LOCATION WILL REMAIN THE SAME.